

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	16.1 LT	40+24.7	0.75-1.20	A-7-6(12)	53	33	31.4	20.5	7.9	40.2	98	81	50	-	-
SS-2	16.1 LT	40+24.7	2.27-2.72	A-7-5(27)	61	26	9.0	7.4	63.4	20.1	100	93	87	-	-
SS-3	16.1 LT	40+24.7	5.31-5.63	A-2-5(0)	41	8	40.4	24.7	24.8	10.1	88	63	35	-	-
SS-4	16.1 LT	40+24.7	9.87-10.32	A-4(0)	27	2	30.6	37.6	21.8	10.1	96	81	46	-	-

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-5	17.1 RT	40+09.2	0.75-1.20	A-7-6(27)	67	43	15.7	19.7	16.4	48.2	97	89	66	-	-
SS-6	17.1 RT	40+09.2	2.38-2.72	A-6(1)	29	13	35.2	28.9	13.8	22.1	97	78	38	-	-
SS-7	17.1 RT	40+09.2	3.79-4.24	A-2-4(0)	26	NP	29.7	44.6	17.6	8.0	98	87	32	-	-

BI-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-14	12.3 LT	40+60.8	0.66-1.11	A-7-5(6)	45	11	33.8	13.7	32.5	20.1	99	73	58	-	-
SS-15	12.3 LT	40+60.8	2.18-2.63	A-5(6)	47	8	17.1	26.5	40.3	16.1	98	87	63	-	-

BI-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-16	14.2 RT	40+49.9	0.67-1.12	A-5(1)	46	7	34.8	26.7	24.4	14.1	100	76	44	-	-
SS-17	14.2 RT	40+49.9	2.19-2.64	A-2-4(0)	40	NP	36.2	33.4	20.4	10.1	98	75	35	-	-
SS-18	14.2 RT	40+49.9	6.93-7.20	A-4(0)	30	NP	30.2	38.0	19.8	12.1	100	86	40	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-8	15.7 LT	41+05.8	0.73-1.18	A-7-5(49)	86	49	8.8	13.5	23.4	54.3	100	96	85	-	-
SS-9	15.7 LT	41+05.8	3.77-4.22	A-5(0)	49	NP	21.3	42.8	25.8	10.1	100	90	48	47.3	-
SS-10	15.7 LT	41+05.8	8.33-8.78	A-2-4(0)	39	3	42.0	26.5	17.4	14.1	91	64	33	-	-

EB2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-11	17.8 RT	40+90.3	2.37-2.75	A-5(0)	42	NP	38.2	27.9	23.8	10.1	96	70	40	-	-
SS-12	17.8 RT	40+90.3	9.90-10.35	A-2-4(0)	28	NP	54.7	27.7	11.6	6.0	98	61	21	-	-
SS-13	17.8 RT	40+90.3	11.42-11.87	A-2-4(0)	31	NP	40.4	36.0	15.6	8.0	99	72	28	-	-