

| -YII- | | |
|-------------------------------------|--------------------------------------|--------------------------------------|
| PI Sta. 10+37.333 | PI Sta. 11+12.831 | PI Sta. 12+44.647 |
| $\Delta = 2^\circ 53' 01.5''$ (LT.) | $\Delta = 14^\circ 44' 57.0''$ (LT.) | $\Delta = 25^\circ 14' 31.1''$ (RT.) |
| L = 74.650 | L = 75.939 | L = 70.489 |
| T = 37.333 | T = 38.181 | T = 35.826 |
| R = 1,483.196 | R = 295.000 | R = 160.000 |
| S.E. = VAR. | S.E. = 0.06 | S.E. = 0.06 |
| | RUNOFF = 48 | RUNOFF = 42 |

ALL WATER LINES OWNED BY DAVIDSON WATER INC.

PROP. 145M OF 150MM PVC WATER PIPE, SDR 21, 1.38 MPA WP
 1 - 200MM X 150MM DI TEE
 1 - 150MM GATE VALVE & VALVE BOX, 1.38 MPA WP
 1 - 150MM 11 1/4° DI BEND
 2 - 150MM 22 1/2° DI BENDS
 CONNECT USING NECESSARY FITTINGS

PROP. 2 - RELOCATE EXISTING WATER METERS
 2 - 150MM X 20MM TAPPING SADDLES
 2 - 20MM CORPORATION STOPS
 19M OF 20MM COPPER WATER PIPE, TYPE K
 CONNECT USING NECESSARY FITTINGS

PROP. 147M OF 150MM PVC WATER PIPE, SDR 21, 1.38 MPA WP
 1 - 150MM 45° DI BEND
 1 - 150MM 11 1/4° DI BEND
 1 - 150MM GATE VALVE & VALVE BOX, 1.38 MPA WP
 1 - 150MM 22 1/2° DI BEND
 CONNECT USING NECESSARY FITTINGS

PROP. 132M - FILL OR REMOVE ABANDONED 200MM PIPE, PVC WATER

PROP. 108M OF 200MM DI WATER PIPE, PC 2.41 MPA WP
 1 - 200MM X 150MM DI CROSS
 1 - 200MM DI PLUG
 1 - 200MM GATE VALVE & VALVE BOX, 1.38 MPA WP
 1 - 200MM 90° DI BEND
 2 - 200MM 11 1/4° DI BEND
 CONNECT USING NECESSARY FITTINGS

PROP. 1 - RELOCATE EXISTING WATER METER
 1 - 200MM X 20MM TAPPING SADDLE
 1 - 20MM CORPORATION STOP
 2M OF 20MM COPPER WATER PIPE, TYPE K
 CONNECT USING NECESSARY FITTINGS

58.78.498\2568b-temp\2568buc 14.pst
 08/03/2004 3:03:57 PM