



150 140 130 120 110 100 90 80 70 60 50 40 30 20 10 0 10 20 30 40 50 60 70 80 90 100 110 120 130 140 150

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-25	70' LT	34+00	2.0-2.5	A-7-6(37)	61	42	1.2	22.5	23.5	52.8	100	100	84	-	-

LEGEND:  
 A: RESIDUAL, BROWN, MEDIUM STIFF, HIGHLY PLASTIC, MOIST, SILTY CLAY  
 B: WEATHERED ROCK (SANDSTONE)  
 C: NON-CRYSTALLINE ROCK (SANDSTONE)

