

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	19' LT	18+88	4.2-5.7	A-7-6(8)	48	27	30.8	23.5	7.1	38.5	100	84	47	18.2	-
SS-2	19' LT	18+88	9.2-10.7	A-2-6(1)	39	21	58.0	15.2	2.4	24.3	100	75	27	-	-
SS-3	19' LT	18+88	14.2-15.7	A-7-5(9)	78	35	20.7	13.2	25.6	40.6	60	51	42	-	-
SS-4	19' LT	18+88	19.2-20.7	A-7-5(14)	59	24	26.0	17.6	36.1	20.3	100	86	60	26.3	-
SS-5	19' LT	18+88	24.2-25.7	A-7-5(8)	43	11	18.5	18.9	50.5	12.2	100	89	68	-	-
SS-6	19' LT	18+88	39.2-40.7	A-4(0)	35	NP	35.1	22.7	34.1	8.1	100	76	48	32.7	-
SS-7	19' LT	18+88	49.2-50.7	A-4(0)	29	NP	35.5	29.8	26.6	8.1	100	78	42	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-11	16' LT	21+38	3.1-4.6	A-7-5(11)	57	27	35.5	14.8	5.1	44.6	100	82	51	25.7	-
SS-12	16' LT	21+38	8.1-9.6	A-7-6(7)	47	21	21.9	28.2	19.5	30.4	89	78	49	-	-
SS-13	16' LT	21+38	18.1-19.6.0	A-4(3)	39	8	23.3	30.2	36.3	10.1	100	86	55	-	-
SS-14	16' LT	21+38	28.1-29.6	A-7-5(22)	77	23	14.4	19.1	38.1	28.4	100	89	73	57.5	-
SS-15	16' LT	21+38	38.1-39.6	A-2-4(0)	30	NP	40.2	29.8	21.9	8.1	100	76	35	-	-
SS-16	16' LT	21+38	48.1-49.6	A-4(0)	34	4	31.6	29.6	30.6	8.1	100	82	45	29.2	-

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-8	16' RT	18+69	13.3-14.8	A-2-7(0)	42	22	58.4	16.4	6.9	18.3	63	38	17	-	-
SS-9	16' RT	18+69	18.3-19.8	A-7-5(12)	59	14	17.2	20.5	44.0	18.3	97	85	67	44.2	-
SS-10	16' RT	18+69	38.3-39.8	A-5(0)	41	NP	25.8	25.6	40.6	8.1	100	82	55	-	-

EB2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-17	19' RT	21+22	23.1-24.6	A-4(0)	39	NP	25.2	26.6	40.2	8.1	100	84	55	39.8	-
SS-18	19' RT	21+22	38.1-39.6	A-4(0)	35	NP	36.9	31.0	26.0	6.1	100	77	38	-	-
SS-19	19' RT	21+22	48.1-49.6	A-2-4(0)	29	NP	48.3	28.8	16.8	6.1	100	68	29	-	-

B1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-24	13' LT	20+09	23.0-24.5	A-4(0)	40	NP	22.4	33.0	34.5	10.1	100	89	54	40.0	-

B1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-20	11' RT	19+96	2.9-4.4	A-7-6(15)	54	32	21.8	25.5	12.2	40.4	100	88	56	27.1	-
SS-21	11' RT	19+96	12.9-14.4	A-7-6(12)	45	19	16.2	20.2	35.3	28.3	100	90	68	-	-
SS-22	11' RT	19+96	27.9-29.4	A-4(5)	40	9	18.6	29.9	35.3	16.2	100	90	62	-	-
SS-23	11' RT	19+96	42.9-44.4	A-4(0)	39	NP	26.1	35.0	26.8	12.1	100	84	47	19.9	-