


300 290 280 270 260 250 240 230 220 210 200 190 180 170 160 150 140 130 120 110 100 90 80 70 60 50 40 30 20 10 0

SOIL TEST RESULTS

| SAMPLE NO. | OFFSET | STATION | DEPTH INTERVAL | AASHTO CLASS. | L.L. | P.L. | % BY WEIGHT | | | | % PASSING SIEVES | | | % MOISTURE | % ORGANIC |
|------------|--------|----------|----------------|---------------|------|------|-------------|---------|------|------|------------------|----|-----|------------|-----------|
| | | | | | | | C. SAND | F. SAND | SILT | CLAY | 10 | 40 | 200 | | |
| SS-33 | 0.0 | 519-00-L | 8.5-10.0 | A-7-5(13) | 56 | 19 | 20 | 19 | 32 | 29 | 100 | 86 | 64 | 25 | |
| SS-37 | 0.0 | 519-00-L | 28.5-30.0 | A-5(0) | 47 | NP | 19 | 31 | 37 | 13 | 99 | 81 | 58 | 27 | |



300 290 280 270 260 250 240 230 220 210 200 190 180 170 160 150 140 130 120 110 100 90 80 70 60 50 40 30 20 10 0