

300 290 280 270 260 250 240 230 220 210 200 190 180 170 160 150 140 130 120 110 100 90 80 70 60 50 40 30 20 10 0

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-5	0.0	489+00.0-L-	18.5-20.0	A-5(10)	55	10	10	36	38	26	99	95	70	26	
SS-8	0.0	489+00.0-L-	33.5-35.0	A-5(2)	48	NP	9	33	35	23	99	91	65	27	

