NOTES

FOR ELASTOMERIC BEARINGS, SEE SPECIAL PROVISIONS.

AT ALL FIXED POINTS OF SUPPORT, NUTS FOR ANCHOR BOLTS ARE TO BE TIGHTENED FINGER TIGHT AND THEN BACKED OFF 1/2 TURN. THE THREAD OF THE NUT AND BOLT SHALL THEN BE BURRED WITH A SHARP POINTED TOOL.

THE 51mm Ø PIPE SLEEVE SHALL BE CUT FROM SCHEDULE 40 PVC PLASTIC PIPE. THE PVC PLASTIC PIPE SHALL MEET

THE PAYMENT FOR THE PIPE SLEEVES SHALL BE INCLUDED IN THE SEVERAL PAY ITEMS.

FOR PAINTED STRUCTURAL STEEL (EXCLUDING AASHTO M270 GRADE 345W), SOLE PLATES, ANCHOR BOLTS NUTS AND WASHERS SHALL BE GALVANIZED IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS.

FOR AASHTO M270 GRADE 345W STRUCTURAL STEEL, SOLE PLATE SHALL BE AASHTO M270 GRADE 345W AND SHALL NOT BE GALVANIZED, ANCHOR BOLTS AND NUTS SHALL BE GALVANIZED IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS.

UP-STATION

—SOLE ₽ ("P")

SOLE PLACEMENT DETAIL

160160

(FIXED)

P2 (4 REQ'D)

SOLE PLATE DETAILS ("P")

160160

(EXPANSION)


P1 (4 REQ'D)

€ 65mm X 150mm \\SLOTS

© 49mm X 57mm \\
SLOTS TAPERED \\
TO 49mm Ø HOLES

ANCHOR BOLTS SHALL MEET THE REQUIREMENTS OF ASTM A449. NUTS SHALL MEET THE REQUIREMENTS OF AASHTO M291M-12 OR AASHTO M292M-2H. WASHERS SHALL MEET THE REQUIREMENTS OF AASHTO M293M. SHOP DRAWINGS

WHEN FIELD WELDING THE SOLE PLATE TO THE GIRDER FLANGE, USE TEMPERATURE INDICATING WAX PENS, OR OTHER SUITABLE MEANS, TO ENSURE THAT THE TEMPERATURE OF THE SOLE PLATE DOES NOT EXCEED 149°C. TEMPERATURES ABOVE THIS MAY DAMAGE THE ELASTOMER.





STATION: 195+74.885 -L-

STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION STANDARD

ELASTOMERIC BEARING DETAILS ====

(STEEL SUPERSTRUCTURE)






THE REQUIREMENTS OF ASTM D1785.

ARE NOT REQUIRED FOR ANCHOR BOLTS. NUTS AND WASHERS. SHOP INSPECTION IS REQUIRED.

ALL SURFACES OF BEARING PLATES SHALL BE SMOOTH AND STRAIGHT.



PROJECT NO. R-2206C LINCOLN-CATAWBA COUNTY

SEAL 022516

160160

(EXPANSION


P4 (4 REQ'D)


€ 49mm X 57mm SLOTS TAPERED TO 49mm Ø HOLES


© 65mm X 150mm | SLOTS

(FIXED)

P3 (4 REQ'D)







TYPE IV

ASSEMBLED BY: M. M. PARSONS DATE: 12/15/03 CHECKED BY: P. ADKINS DATE: 2/04 REV. 7/17/98 RWW/LES REV. 8/16/99 MAB/LES REV. 10/17/00 RWW/LES DRAWN BY: EEM 10/95 CHECKED BY: PEK 10/95

STR. #1

STD. NO. EB2SM