



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L.I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-101	CL	14+05	0-4	A-7-6(11)	43	25	20.4	25.7	9.5	44.4	99	89	56		
S-102	CL	15+05	0-2.6	A-7-5(26)	68	30	5.1	17.8	16.6	60.6	100	98	81		
S-103	CL	15+05	2.6-7.1	A-4(5)	40	9	9.1	38.8	31.9	20.2	100	98	60		

SYSTEM \$\$\$\$\$\$
 DGN \$\$\$\$\$\$
 PLOT \$\$\$\$\$\$
 PRINT \$\$\$\$\$\$
 \$\$\$\$\$\$