



BASE MOUNTED CABINET INSTALLATION

N.T.S.

NOTES:

1. THE SPACE BETWEEN THE BASE OF THE CABINET AND THE FOUNDATION SHALL BE SEALED ON ALL SIDES WITH A PERMANENT, FLEXIBLE, WATERPROOF SEALING MATERIAL.
2. CONDUITS SHALL NOT EXTEND MORE THAN 4" ABOVE FOUNDATION.



HNTB NORTH CAROLINA, P.C.
343 E. Six Forks Road, Suite 200
Raleigh, North Carolina 27609

	CABINET DETAILS		SEAL
	DIVISION 07 ORANGE COUNTY HILLSBOROUGH PLAN DATE: OCTOBER 2003 REVIEWED BY: E.T. GARRETT PREPARED BY: E.T. GARRETT REVIEWED BY: H.L. WINSTEAD		NORTH CAROLINA PROFESSIONAL ENGINEER H. L. WINSTEAD, P.E. 07983
SCALE 	REVISIONS _____ _____ _____	INIT. DATE _____ _____ _____	SIGNATURE DATE 9/14/04 CADD FILE NAME: tms-27.dgn