



**PROP. 72M OF 300MM DI SEWER PIPE, PC 2.41 MPA  
 INSTALL ALONG SAME ALIGNMENT**

**PROP. 160M OF 300MM DI WATER PIPE, PC 2.41 MPA  
 1- 300MM - 22.5° DI BEND  
 1- 300MM - 11.25° DI BEND  
 CONNECT USING NECESSARY FITTING**

**FILL OR REMOVE 168M ABANDONED 300M PIPE, (DI- WATER)**

**EXISTING MANHOLE NO. 1D  
 STA. 1+13.3**

**PROP. 41.8 M OF 300MM DI SEWER PIPE, PC 2.41 MPA**

**PROP. 1200MM MANHOLE NO. 1B STA. 0+39.3  
 -L- REV. STA. 49+04.86  
 28.99M RT**

**PROP. 1200MM MANHOLE NO. 1C STA. 0+81.1  
 -L- REV. STA. 49+46.38  
 25.60M RT.**

**PROP. 32.2M OF 300MM DI SEWER PIPE, PC 2.41 MPA**

**BREAK DOWN & REBUILD EXISTING MANHOLE NO. 1A  
 STA. 0+00.00**

**PROP. 39.3M OF 300MM DI SEWER PIPE, PC 2.41 MPA**

**FILL OR REMOVE 120M ABANDONED 300M PIPE, (CONC. - SEWER)**

MATCHLINE SEE STA. 47+60 -L-

MATCHLINE STA. 51+20 -L- SEE SHEET UC-8

PJ.= 11+19.908  
 $\Delta = 55^{\circ}47'34.4''$  RT  
 T = 119.908 M  
 L = 220.559 M  
 R = 226.500 M  
 SUPER= 0.05

SEE SHEET 39 FOR -L- PROFILE  
 SEE SHEET 49 FOR -Y7- PROFILE

R:\1\22-JAN-2004\BIB\2911\2911as15a\UC-6.DWG  
 042587