


**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-37	11M LT	51+00	0.15-1.31	A-4(2)	33	7	16.5	24.7	32.6	26.2	80	72	51	-	-
S-38	11M LT	51+80	0.10-3.75	A-4(3)	30	7	11.9	30.0	36.0	22.1	98	92	66	-	-
SS-109	29M LT	52+80	0.15-0.60	A-4(2)	32	9	19.8	19.0	28.9	32.3	72	62	48	-	-
S-39	11M LT	53+80	0.30-2.30	A-4(0)	25	3	20.1	28.6	29.2	22.1	94	85	52	-	-



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-40	11M LT	55+40	0.10-1.50	A-7-6(21)	49	20	3.4	8.9	33.4	54.3	98	96	89	-	-
SS-110	25M LT	56+20	1.25-1.70	A-6(7)	34	15	15.2	23.6	26.9	34.3	94	84	63	-	-
SS-111R	25M LT	56+20	2.77-3.19	A-4(2)	30	6	8.1	33.3	36.4	22.2	95	91	64	-	-

