



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-185	11M LT	125+00	1.28-1.58	A-6(5)	39	12	24.3	23.5	30.0	22.3	100	86	56	-	-
SS-186	11M LT	125+00	2.65-3.10	A-4(0)	28	7	39.3	22.9	23.7	14.2	97	69	41	-	-
CBR-2	15M LT	125+60	1.50-3.00	A-4(1)	26	9	33.9	18.0	23.8	24.2	94	71	49	-	-
S-145	15M LT	126+00	3.40-5.65	A-7-6(21)	49	25	6.3	16.4	37.0	40.4	99	96	81	-	-
S-142	17M LT	126+60	0.00-1.65	A-7-6(26)	57	35	6.9	21.2	23.4	48.5	98	95	75	-	-
S-143	17M LT	127+40	0.45-2.45	A-7-6(11)	42	20	19.0	15.8	34.9	30.3	92	82	63	-	-
S-144	17M LT	127+40	2.45-4.38	A-7-6(11)	42	18	19.0	14.1	36.6	30.3	99	88	68	-	-

