





**BM # 14**  
**R/R SPIKE IN BASE OF POWER POLE, 47.95m RIGHT**  
**OF BASELINE -L- 150+40.000 ELEV. 155.615m**



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-79	11M LT	76+40	0.00-1.40	A-6(7)	36	14	15.8	14.7	33.1	36.4	83	74	61	-	-
S-80	11M LT	77+00	0.00-2.50	A-6(7)	38	12	13.1	16.2	32.3	38.4	89	80	66	-	-
S-81	11M LT	77+00	2.50-4.10	A-4(0)	29	8	34.5	21.6	19.6	24.2	68	50	36	-	-
SS-162	11M LT	77+80	0.00-1.19	A-7-6(13)	43	22	12.9	19.2	25.6	42.3	93	86	68	-	-
SS-163	11M LT	77+80	2.50-6.20	A-6(8)	37	13	10.9	17.3	31.5	40.3	94	88	71	-	-



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-82	11M LT	78+60	0.00-0.60	A-7-6(32)	67	44	7.5	10.3	29.7	52.5	86	81	73	-	-
S-83	11M LT	78+60	0.60-3.10	A-4(1)	24	7	13.7	32.7	29.3	24.2	90	80	53	-	-
SS-164	11M LT	79+40	0.90-2.10	A-7-6(13)	59	38	17.7	17.5	16.3	48.4	69	60	47	-	-
SS-165	11M LT	79+40	2.10-4.64	A-2-6(0)	33	16	45.4	21.8	8.7	24.2	53	35	20	-	-
S-84	11M LT	80+20	0.00-4.32	A-7-6(27)	55	27	2.4	12.3	36.8	48.5	100	99	88	-	-
S-84A	11M LT	81+20	0.00-1.20	A-6(10)	36	15	8.3	16.4	47.1	28.3	94	87	75	-	-
S-85	11M LT	82+00	0.00-1.00	A-2-6(0)	31	12	53.3	19.2	15.4	12.1	85	50	26	-	-

