

FUTURE PROJECT U-4421



PROJECT REFERENCE NO. U-0620	SHEET NO. UC-4
DESIGNED BY: DMP	
DRAWN BY: DMP	
CHECKED BY: DMP	
APPROVED BY:	
REVISED:	
NORTH CAROLINA DEPARTMENT OF TRANSPORTATION	
DESIGN SERVICES UNIT PHONE: (919) 250-4128 FAX: (919) 250-4119	UTILITY CONSTRUCTION PLANS ONLY

UTILITY CONSTRUCTION

PROP. - 1 - 12 INCH x 12 INCH TAPPING SLEEVE, VALVE, AND VALVE BOX, 200 PSI WP
2 - 12 INCH 45° DI RESTRAINED JOINT BEND(S)
180 LF OF 12 INCH DI RESTRAINED JOINT WATER PIPE, PC 350
1 - 12 INCH 22.5° DI RESTRAINED JOINT BEND
1 - 12 INCH DI TRANSITION COUPLING (DI TO PVC)
1 - 12 INCH DI RESTRAINED JOINT PLUG

PROP. - 2 - RELOCATE EX. WATER METER(S)
20 LF OF 1 INCH PE WATER TUBING, SDR 9, 200 PSI WP
2 - 12 INCH x 1 INCH TAPPING SADDLE
2 - 1 INCH CORPORATION STOP
CONNECT USING NECESSARY FITTINGS

PROP. - 3 - RELOCATE EX. WATER METER
30 LF OF 1 INCH PE WATER TUBING, SDR 9, 200 PSI WP
1 - 6 INCH x 1 INCH TAPPING SADDLE
1 - 1 INCH CORPORATION STOP
CONNECT USING NECESSARY FITTINGS

PROP. 390 LF FILL OR REMOVE ABANDONED 12 INCH PIPE, PVC WATER

PROP. - 4 - RELOCATE EX. FIRE HYDRANT
1 - 12 INCH x 8 INCH DI RESTRAINED JOINT TEE
1 - 8 INCH GATE VALVE AND VALVE BOX, 250 PSI WP
130 LF OF 8 INCH DI RESTR. JOINT WATER PIPE, PC 350
1 - 8 INCH GATE VALVE AND VALVE BOX, 250 PSI WP
1 - 8 INCH x 6 INCH DI RESTRAINED JOINT REDUCER
10 LF OF 6 INCH DI RESTR. JOINT WATER PIPE, PC 350

PROP. - 220 LF OF 12 INCH PVC WATER PIPE, (C-900), DR 18, 150 PSI WP
12 INCH DI TRANSITION COUPLING (DI TO PVC)

PROP. 30 LF OF 8 INCH DI SEWER PIPE, PC 350

EXIST. MANHOLE STA 1+60, LINE PS 401

EX. MANHOLE STA 0+00, LINE PS 401

PROP. MANHOLE PSI STA 1+30, LINE PS 401

PROP. - 60 LF 24 INCH DI RESTRAINED JOINT WATER PIPE, PC 250
4 24 INCH DI RESTRAINED JOINT 45° BENDS

PROP. 130 LF OF 8 INCH DI SEWER PIPE, PC 350

