


Rev. 3/5/01



### SOIL TEST RESULTS

| SAMPLE NO. | OFFSET   | STATION | DEPTH INTERVAL | AASHTO CLASS. | L.L. | P.L. I. | % BY WEIGHT |         |      |      | % PASSING SIEVES |    |     | % MOISTURE | % ORGANIC |
|------------|----------|---------|----------------|---------------|------|---------|-------------|---------|------|------|------------------|----|-----|------------|-----------|
|            |          |         |                |               |      |         | C. SAND     | F. SAND | SILT | CLAY | 10               | 40 | 200 |            |           |
| SS-3       | 12.0 LT. | 18+70.0 | 4.00-5.00      | A-6(II)       | 36   | 18      | 13.7        | 14.9    | 39.2 | 32.2 | 95               | 85 | 73  |            |           |
| SS-4       | 12.0 LT. | 18+70.0 | 9.00-10.00     | A-6(2)        | 29   | 11      | 15.7        | 19.5    | 36.6 | 28.2 | 67               | 60 | 47  |            |           |

\$\$\$\$\$SYTIME\$\$\$\$\$  
 \$\$\$DOCS\$\$\$\$\$  
 \$\$\$USERNAME\$\$\$\$\$