



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-10	15 RT	20+50	4.3-5.3	A-7-5(13)	68	21	13	29	14	44	100	95	64
SS-11	15 RT	20+50	9.3-10.3	A-2-5(01)	43	NP	55	29	8	8	91	57	18
SS-12	15 RT	20+50	19.3-20.3	A-2-5(01)	51	NP	35	49	10	6	95	84	21
SS-13	15 LT	22+00	3.9-4.9	A-7-5(11)	64	18	18	25	15	42	99	89	61