

SOIL TEST RESULTS													
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-10	32	30+50	2.0-2.5	A-2-6(0)	37	11	46.8	23.4	15.6	14.1	56	38	19

