



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS- 5	-20	27+00	6.0-7.5	A-7-6(7)	50	31	34.1	18.4	21.3	26.2	82	60	42
SS- 6	-20	27+00	11.5-12.0	A-4(4)	35	10	2.0	46.0	27.7	24.2	100	100	59

-L-