

SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS- 1	20	22+00	1.5-3.0	A-7-6(10)	41	23	20.8	21.0	28.0	30.3	87	75	56
SS- 2	20	22+00	6.5-8.0	A-4(0)	18	NP	8.7	39.8	36.4	16.1	100	95	62
SS- 3	20	22+00	11.5-13.0	A-4(2)	26	6	6.1	34.7	41.1	18.2	100	97	70
SS- 4	20	22+00	16.5-18.0	A-4(0)	33	NP	36.5	21.6	35.8	6.1	100	72	48

