


Rev. 3/16/01



SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
S-7	24' RT	22+50	0.50-3.50	A-6(9)	33	13	0.6	28.6	48.4	22.3	96	96	80	-	-

\*\*\*\*\*SYTIME\*\*\*\*\*  
\*\*\*\*\*USERNAME\*\*\*\*\*