

**EB1-A**

<b>SOIL TEST RESULTS</b>													
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C.SAND	F.SAND	SILT	CLAY	10	40	200
SS-4	15.0' LT	43+10	4.3-5.8	A-6(4)	39	15	19.8	38.2	13.9	28.0	100	94	46
SS-5	15.0' LT	43+10	9.3-10.8	A-2-6(0)	39	17	70.5	12.6	4.9	12.0	54	22	10
SS-6	15.0' LT	43+10	14.3-15.8	NOT ENOUGH SAMPLE			67.1	22.0	8.9	2.0	40	19	5
SS-7	15.0' LT	43+10	21.8-23.3	A-2-4(0)	29	NP	26.0	53.7	16.3	4.0	100	91	27

**EB1-B**

<b>SOIL TEST RESULTS</b>													
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C.SAND	F.SAND	SILT	CLAY	10	40	200
SS-8	25.0' RT	42+76	4.7-6.2	A-2-4(0)	23	NP	27.0	51.7	13.3	8.0	86	77	24
SS-9	25.0' RT	42+76	15.4-16.2	A-2-4(0)	25	NP	11.4	78.1	8.5	2.0	100	97	24

**EB2-A**

<b>SOIL TEST RESULTS</b>													
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C.SAND	F.SAND	SILT	CLAY	10	40	200
SS-10	13.0' LT	44+85	9.6-11.1	A-4(0)	25	NP	21.8	48.2	19.9	10.0	100	92	37
SS-11	13.0' LT	44+85	19.6-21.1	A-2-4(0)	27	NP	28.6	48.8	18.5	4.0	100	92	28

**EB2-B**

<b>SOIL TEST RESULTS</b>													
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)		
							C.SAND	F.SAND	SILT	CLAY	10	40	200
SS-1	13.0' RT	44+52	2.2-3.7	A-2-4(0)	23	6	29.8	42.0	12.1	16.0	79	69	26
SS-2	13.0' RT	44+52	7.2-8.7	A-2-4(0)	25	NP	20.4	59.5	18.1	2.0	97	90	26
SS-3	13.0' RT	44+52	12.2-13.7	A-2-4(0)	29	NP	27.4	54.1	16.5	2.0	100	93	25