

EB1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-8	16' LT	17+44	12.0-13.5	A-2-6(0)	31	11	51.3	20.6	18.0	10.1	42	25	13	-	-

EB1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-1	12' RT	17+44	1.9-3.4	A-7-6(7)	43	16	18.0	22.4	39.4	20.2	87	77	57	19	-
SS-2	12' RT	17+44	6.9-8.4	A-4(4)	30	9	13.7	29.5	36.6	20.2	94	86	62	-	-
SS-3	12' RT	17+44	11.9-13.4	A-5(8)	42	9	9.7	30.3	49.9	10.1	100	95	74	-	-
SS-4	12' RT	17+44	16.9-18.4	A-7-5(11)	46	15	8.9	33.5	45.5	12.1	100	95	70	-	-
SS-5	12' RT	17+44	21.9-23.4	A-7-5(11)	50	16	14.7	24.2	50.9	10.1	92	82	65	24	-
SS-6	12' RT	17+44	26.9-28.4	A-5(8)	43	10	8.9	33.1	47.9	10.1	100	95	73	-	-
SS-7	12' RT	17+44	36.9-38.4	A-4(8)	40	10	8.9	28.5	46.5	16.2	100	94	75	-	-

B1-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-18	7' LT	17+93	27.0-28.5	A-7-6(15)	48	19	9.3	21.2	43.2	26.3	96	90	75	-	-

B1-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-14	8' RT	17+93	12.0-13.5	A-7-5(14)	48	17	6.9	26.9	48.1	18.2	100	96	76	-	-
SS-15	8' RT	17+93	17.0-18.5	A-7-6(24)	55	27	5.3	25.7	46.9	22.2	100	97	82	-	-
SS-16	8' RT	17+93	27.0-28.5	A-7-6(16)	48	19	7.7	24.4	45.7	22.2	100	96	78	-	-
SS-17	8' RT	17+93	37.0-38.5	A-7-6(13)	49	20	16.0	26.3	45.7	12.1	100	88	66	-	-

B2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-19	8' LT	18+42	2.4-3.9	A-7-5(11)	49	17	7.7	24.8	45.3	22.2	83	79	65	-	-
SS-20	8' LT	18+42	12.4-13.9	A-7-6(15)	48	19	6.1	30.5	43.2	20.2	98	95	75	-	-
SS-21	8' LT	18+42	27.4-28.9	A-7-6(20)	49	20	5.7	16.2	51.9	26.3	100	97	87	-	-

B2-B

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-22	7' RT	18+42	7.0-8.5	A-7-6(12)	48	20	5.5	26.9	45.5	22.2	80	77	64	-	-
SS-23	7' RT	18+42	12.0-13.5	A-7-5(19)	51	21	3.8	25.3	48.7	22.2	96	94	80	-	-

EB2-A

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			%	%
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
SS-9	13' LT	18+91	4.2-5.7	A-7-6(19)	53	27	11.3	18.0	42.4	28.3	91	84	70	-	-
SS-10	13' LT	18+91	9.2-10.7	A-3(0)	23	NP	53.9	37.0	5.1	4.0	86	64	10	-	-
SS-11	13' LT	18+91	14.2-15.7	A-7-6(14)	48	20	9.1	29.1	39.6	22.2	98	93	71	19	-
SS-12	13' LT	18+91	24.2-25.7	A-7-6(15)	49	21	7.9	26.5	45.5	20.2	96	92	72	-	-
SS-13	13' LT	18+91	29.2-30.7	A-7-5(11)	45	14	9.3	31.1	43.4	16.2	100	95	74	-	-