



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL.	PL I.	% BY WEIGHT							
							C. SAND	F. SAND	SILT	CLAY				
SS-1	2.5 LT	12+23	0.15-0.45	A-2-4(0)	27	NP	30	50	12	8	10	96	84	25
SS-2	2.5 LT	12+23	2.46-2.76	A-2-4(0)	31	NP	35	53	10	2	96	96	77	18
SS-5	5 LT	11+82.5	1.19-1.49	A-6(4)	37	12	16	34	18	32	90	84	49	
SS-6	5 LT	11+82.5	2.71-2.89	A-1-6(0)	26	NP	46	35	11	8	52	36	13	

20 15 10 5 CL 5 10