

SOIL TEST RESULTS														
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	SUITABILITY	L.P.	BY WEIGHT			PASSING SIEVES			MOISTURE	ORGANIC	
						T. SOL	SAND	SILT	CLAY	NO. 10	NO. 40			NO. 200
SS-21	20M RT	30+32	38-4.48	A-5(4)	6	6	6.6	24.2	57.3	12.1	100	96	80	
SS-22	20M RT	39+32	42-7.72	A-5(6)	4	8	11.3	32.1	44.6	12.1	97	91	65	
SS-23	20M RT	39+32	94-9.24	A-5(3)	4	6	27.2	23.8	39.1	10.1	98	78	56	
BS-24	20M RT	30+32	27-11.10	A-5(6)	0	0	14.0	17.0	46.8	22.3	86	80	47	



PROJECT REFERENCE NO. R-977A
SHEET NO. X-239

