


### SOIL TEST RESULTS

| SAMPLE NO. | OFFSET | STATION   | DEPTH INTERVAL | AASHTO CLASS. | L.L. | P.L. I. | % BY WEIGHT |         |      |      | % PASSING SIEVES |    |     |
|------------|--------|-----------|----------------|---------------|------|---------|-------------|---------|------|------|------------------|----|-----|
|            |        |           |                |               |      |         | C. SAND     | F. SAND | SILT | CLAY | 10               | 40 | 200 |
| SS-30      | 36' RT | DET-17+11 | 1.5-2.5        | A-2-7(1)      | 42   | 14      | 18          | 44      | 6    | 32   | 76               | 71 | 33  |
| SS-31      | 36' RT | DET-17+11 | 4.0-5.0        | A-2-4(0)      | 39   | 10      | 23          | 48      | 3    | 26   | 56               | 50 | 20  |
| SS-32      | 36' RT | DET-17+11 | 6.5-7.5        | A-7-6(6)      | 45   | 16      | 13          | 40      | 13   | 34   | 95               | 90 | 50  |
| SS-33      | 36' RT | DET-17+11 | 9.0-10.0       | A-7-5(4)      | 43   | 13      | 14          | 46      | 10   | 30   | 100              | 96 | 47  |
| SS-34      | 36' RT | DET-17+11 | 14.0-15.0      | A-1-b(0)      | 40   | NP      | 35          | 29      | 20   | 16   | 39               | 31 | 17  |
| SS-35      | 36' RT | DET-17+11 | 19.0-20.0      | A-2-4(0)      | 36   | 5       | 24          | 52      | 6    | 18   | 61               | 55 | 19  |
| SS-36      | 36' RT | DET-17+11 | 24.0-25.0      | A-2-4(0)      | 30   | NP      | 31          | 43      | 14   | 12   | 94               | 82 | 29  |
| SS-37      | 36' RT | DET-17+11 | 28.0-29.0      | A-2-4(0)      | 38   | 10      | 15          | 55      | 4    | 26   | 71               | 68 | 27  |
| SS-39      | 36' RT | DET-17+11 | 38.0-39.0      | A-1-b(0)      | 35   | NP      | 33          | 45      | 4    | 18   | 39               | 32 | 11  |



SYSTEMS DESIGN CONSULTANTS INC. 10000 W. CENTURY BLVD. SUITE 1000 LOS ANGELES, CA 90045  
 TEL: (310) 554-2200 FAX: (310) 554-2201 WWW: WWW.SDCON.COM