

FOUNDATION COVER 1

△ NOTES

DIMENSIONS SHOWN ARE MINIMUM REQUIRED TO COVER TYPE M1
AND M2 FOUNDATIONS. VERIFY EXISTING FOUNDATION DIMENSIONS
BEFORE FABRICATION.

CUT GROUNDING CONDUCTOR LONG ENOUGH FOR COVER TO BE REMOVED WITHOUT DISCONNECTING AT THE GROUNDING LUG.

SEE STANDARD DRAWING NUMBER 1405.01 SHEETS 2 AND 3 FOR STANDARD FOUNDATIONS TYPE M1 AND M2.

SELECT APPROPRIATE COLLAR SIZE FOR TRAFFIC SIGNAL POLE AND PEDESTRIAN POST-TOP LIGHT POLE.

SEE TABLE SHOWN IN "POST-TOP LGT W/ BREAKAWAY BASE" SPECIAL PROVISIONS FOR DIFFERENT ELECTRICAL OPERATING REQUIREMENTS OF THE HADCO FIXTURES USED IN PEDESTRIAN POST-TOP LGTS AND ON TRAFFIC SIGNAL POLES.

