




SECTION ALONG © SURVEY








GENERAL NOTES

SLOPE PROTECTION SHALL BE PLACED UNDER THE ENDS OF THE BRIDGE AS SHOWN IN THE DETAILS. STRAIGHT EDGING WILL NOT BE REQUIRED UNLESS, IN THE OPINION OF THE ENGINEER, VISUAL INSPECTION INDICATES A NEED FOR IT. METHOD OF MEASUREMENT AND BASIS OF PAYMENT SHALL BE AS PRESCRIBED IN SECTION 462 OF THE STANDARD SPECIFICATIONS, FOR BERM WIDTH, SEE GENERAL DRAWING.


SLOPE PROTECTION SHALL CONSIST OF 100mm POURED-IN-PLACE CONCRETE PAVING AS SHOWN IN THE DETAILS ON THIS SHEET. CONCRETE SHALL BE CLASS "B". THE CONCRETE SURFACE SHALL BE FLOATED WITH A WOODEN FLOAT AND FINISHED. WELDED WIRE FABRIC REINFORCING SHALL BE 152 X 152 - W9.1 X W9.1, 1520mm WIDE. SLOPE PROTECTION SHALL BE POURED IN 1520mm STRIPS AS SHOWN IN THE "POURING DETAIL" WITH 600mm LONG #13 BARS PLACED ALONG THE SLOPE BETWEEN STRIPS AT 450mm MAXIMUM SPACING. SLOPE PROTECTION MAY BE POURED IN ALTERNATE 1220mm AND 1520mm STRIPS AS SHOWN IN THE "OPTIONAL POURING DETAIL" WITH ADJACENT RUNS OF WELDED WIRE FABRIC LAPPING AT LEAST 152mm. THE COST OF THE WELDED WIRE FABRIC AND #13 BARS, IF USED, SHALL BE INCLUDED IN THE CONTRACT UNIT PRICE BID PER SQUARE METER FOR SLOPE PROTECTION.

BRIDGE @ STA. 9+28.021 -FLYOVER-	100 mm SLOPE PROTECTION	WELDED WIRE FABRIC 1520mm WIDE	
	SQUARE METERS	APPROX. METERS	
END BENT 1	282.2	254.0	
END BENT 2	337.0	303.3	

• QUANTITY SHOWN IS BASED ON 1520mm POURS.



END BENT 1 SHOWN, END BENT 2 SIMILAR BY ROTATION



PROJECT NO. R-2552C

JOHNSTON

COUNTY STATION: POS 16+52.599 -Y4-

POC 9+28.021 -FLYOVER-

STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION

SLOPE PROTECTION DETAILS

	REVISIONS				SHEET NO.
BY:	DATE:	NO.	BY:	DATE:	5-426
		3			TOTAL SHEETS
		4			431

ASSEMBLED BY : LGH DATE : II-04 CHECKED BY : JTG DATE : I-05 REV. 10/17/00 REV. 7/10/01 REV. 5/7/03 RWW/LES LES/RDR RWW/JTE DRAWN BY: ELR 5/92 CHECKED BY: GRP 6/92

D-1748.31

STD. NO. SP1SM