



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL I.	% BY WEIGHT				% PASSING SIEVES			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-41	25m RI	65+80	0.10-0.40	A-2-4(0)	14	NP	31.5	49.2	11.2	8.0	100	88	23		
SS-42	25m RI	65+80	0.72-1.17	A-6(1)	30	12	27.9	38.2	9.8	24.1	100	88	37		
SS-43	25m RI	65+80	2.24-2.69	A-6(2)	37	14	25.3	37.6	13.1	24.1	100	90	40	20.9	
SS-44	25m RI	65+80	3.76-4.21	A-2-4(0)	19	NP	52.0	34.7	9.2	4.0	100	67	17		
SS-45	25m RI	65+80	5.28-5.73	A-2-6(2)	39	23	37.6	32.7	9.6	20.1	100	90	31		
SS-349	CL	65+66	2.55-3.00	A-2-6(1)	34	13	27.9	41.4	20.6	10.1	100	87	34	21.3	
SS-350	CL	65+66	4.07-4.52	A-2-6(0)	28	13	45.5	33.5	2.8	18.2	100	79	23		
SS-351	CL	65+66	5.30-5.75	A-7-5(17)	59	23	8.5	27.3	25.9	38.4	100	95	70		
SS-352	CL	65+66	7.11-7.56	A-7-5(27)	70	39	4.4	33.5	23.6	38.4	100	99	68	46.5	
SS-353	CL	65+66	10.13-10.58	A-5(0)	46	NP	13.5	48.3	30.1	8.1	100	95	45	35.1	