



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S-21	0	1+80	2.00-2.60	A-7-6(9)	59	31	43.5	13.9	4.3	38.3	99	70	44
S-22	0	1+80	3.50-4.00	A-7-6(46)	79	53	10.3	12.5	12.8	64.5	100	94	80
S-23	0	1+80	6.00-7.00	A-2-7(7)	12	52	54.2	14.9	2.7	28.2	93	55	32