



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES			% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200	
S-185	6	9+20	0.00-0.50	A-4(0)	30	NP	33.0	32.1	25.8	9.0	98	79	39	6.8
S-186	6	9+20	1.00-1.45	A-7-6(4)	47	24	41.6	22.5	9.8	26.1	96	70	38	
S-187	6	9+20	2.50-3.00	A-7-6(22)	57	37	21.7	16.3	15.9	46.2	99	86	65	
S-188	6	9+20	3.60-4.15	A-7-6(6)	53	33	51.2	10.9	6.7	31.1	96	63	37	

