



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES			% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200	
PS-550	0	118+40	0.00-0.45	A-2-4(0)	22	NP	57.6	32.5	6.9	3.1	95	58	13	1.7
PS-551	0	118+70	0.00-0.55	A-2-4(0)	26	NP	44.6	35.0	11.3	9.2	95	68	24	3.1

- Ⓐ COASTAL PLAIN, GRAY, MEDIUM DENSE, MOIST, COARSE SAND
- Ⓑ ALLUVIAL, LIGHT GRAY AND WHITE, VERY LOOSE TO LOOSE, SATURATED, COARSE SAND WITH TRACE TO LITTLE ORGANIC MATERIALS
- Ⓒ COASTAL PLAIN, ORANGE-RED, TAN, PINK, AND GRAY, LOOSE TO DENSE, WET, CLAYEY SAND

