



**SOIL TEST RESULTS**

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S- 321	18	112+25	3.20-3.60	A-7-5(7)	54	11	17.3	27.0	19.4	36.3	100	93	61