



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-516	-63	116+05	1.12-1.57	A-2-7(15)	74	43	59.7	8.9	3.2	28.2	90	45	29
SS-517	-63	116+05	2.64-3.09	A-7-6(23)	53	24	1.0	42.5	14.1	42.3	100	99	84
SS-518	-63	116+05	5.68-6.13	A-4(0)	30	NP	9.9	49.6	24.4	16.1	100	96	49
S-313	-2.5	115+99	1.80-2.20	A-2-7(2)	57	33	66.0	9.0	3.8	21.2	90	39	23
S-314	-2.5	115+99	3.80-4.20	A-7-6(8)	42	15	11.0	46.9	8.8	33.3	100	92	60
S-315	-2.5	115+99	6.80-7.20	A-7-6(11)	47	23	17.6	36.9	15.2	30.3	100	91	59
S-316	-2.5	115+99	8.00-8.40	A-4(0)	35	5	28.9	37.5	15.4	18.2	100	83	41

