



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL.	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S- 545	-1.0	110+80	0.50-1.00	A-7-5(37)	14	36	6.3	11.6	21.1	61.0	100	97	85

Ⓐ ALLUVIAL GRAY-BROWN, STIFF, MOIST, SANDY CLAY