


# -LOOP C-



SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS-133	-19	0+25	1.15-1.60	A-4(0)	17	8	42.7	20.5	18.6	18.1	98	70	40
SS-134	-19	0+25	2.67-3.12	A-7-6(7)	46	25	27.2	22.6	14.0	36.3	83	70	45
SS-135	-19	0+25	4.13-4.58	A-2-4(0)	28	NP	25.4	50.4	16.2	8.1	88	77	29
S-131	0	1+00	0.50-1.00	A-4(0)	18	6	32.2	32.4	19.2	16.1	100	83	41
S-132	0	1+00	3.00-4.00	A-4(0)	21	10	32.8	33.4	15.6	18.1	97	78	38
S-86	0	2+00	1.00-2.00	A-2-4(0)	16	NP	36.0	35.8	15.1	13.1	98	77	34
SS-79	0	3+00	1.14-1.59	A-2-6(1)	35	17	42.8	26.5	8.6	22.1	100	95	34
SS-80	0	3+00	2.66-3.11	A-2-7(3)	54	29	42.8	24.3	2.8	30.1	91	66	33
SS-81	0	3+00	4.18-4.63	A-7-6(10)	44	20	12.7	33.7	19.5	34.1	99	93	59

# SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S-85	0	3+80	0.50-1.00	A-6(3)	39	14	32.1	25.7	11.0	31.1	97	78	45
SS-113	-15	5+00	1.17-1.62	A-2-4(0)	27	NP	38.5	29.2	14.2	18.1	74	55	27
SS-114	-15	5+00	2.69-3.14	A-7-6(16)	58	39	14.3	37.3	10.2	38.3	98	94	52
SS-115	-15	5+00	4.21-4.66	A-2-4(0)	16	6	17.7	54.0	16.2	12.1	88	84	34
SS-116	-7	5+60	1.11-1.56	A-4(0)	12	NP	27.2	35.4	31.3	6.0	98	82	45
SS-117	-7	5+60	5.67-6.12	A-2-4(0)	30	NP	30.0	52.8	13.2	4.0	100	84	25

# -LOOP C-

