


# -Y5 DETOUR-



## SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES			% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200	
SS-170	0	10+30	1.12-1.57	A-2-6(1)	36	14	43.4	28.8	5.7	22.1	100	82	30	
SS-171	0	10+30	2.69-3.14	A-2-4(0)	21	NP	53.4	36.4	5.1	5.0	100	75	23	
S-172	0	11+00	0.50-1.00	A-3(0)	19	NP	53.3	39.8	3.8	3.0	100	77	10	3.6
SS-357	0	11+80	2.45-2.88	A-2-4(0)	14	NP	58.6	28.6	9.8	3.0	97	64	16	
SS-358	0	11+80	5.49-5.94	A-2-7(1)	55	34	69.0	8.1	3.8	19.1	77	29	19	
S-176	0	12+60	0.50-1.00	A-2-6(1)	33	17	43.5	28.1	7.3	21.1	98	75	31	
S-177	0	12+60	2.00-3.00	A-2-6(1)	34	18	52.5	17.9	7.4	22.1	74	45	24	
S-178	0	12+60	3.50-4.00	A-6(2)	36	17	16.9	49.3	7.6	26.2	93	83	36	
CBR-2	0	13+15	0.00-2.00	A-2-6(1)	40	19	48.4	17.5	6.0	28.1	76	49	27	

# -Y6-

