



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.L. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS- 359	-3	25+60	1.08-1.53	A-7-5(10)	58	27	23.8	27.6	14.4	342.0	96	82	50
SS- 360	-3	25+60	4.12-4.57	A-7-5(10)	56	23	25.8	18.9	11.0	44.3	94	79	54
SS- 361	-3	25+60	5.64-5.76	A-4(0)	16	NP	26.2	37.1	24.4	12.2	93	79	42
SS- 362	-3	25+60	8.68-9.13	A-2-4(0)	25	NP	28.6	46.4	12.8	12.2	75	63	23
S- 104	0	27+20	0.50-1.00	A-1-b(0)	21	NP	45.5	29.8	14.6	10.1	55	39	16
S- 105	0	27+20	2.00-3.00	A-7-6(12)	51	29	24.4	22.6	14.8	38.3	93	79	53
S- 106	0	27+20	3.50-4.00	A-2-4(0)	20	NP	39.9	34.6	13.4	12.1	97	73	29
SS- 309	10	27+65	1.10-1.55	A-7-6(20)	66	37	12.5	19.0	16.0	52.5	83	77	60
SS- 310	10	27+65	2.62-3.07	A-7-5(22)	78	23	6.7	32.1	18.9	42.4	100	96	72
SS- 311	10	27+65	4.14-4.59	A-4(0)	32	NP	16.3	52.3	13.2	18.2	100	95	40
SS- 312	10	27+65	5.66-6.11	A-7-5(15)	76	13	2.4	38.5	40.9	18.2	100	100	71

① ROADWAY EMBANKMENT, BROWN, MEDIUM DENSE, DRY, SAND WITH ABC