


SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
S- 226	-10	125+48	1.90-2.30	A-2-4(0)	23	8	56.8	19.7	11.5	12.0	97	58	25
S- 227	-10	125+48	4.10-4.50	A-6(3)	37	17	26.1	40.3	9.5	24.1	100	83	42
S- 228	-10	125+48	6.20-6.40	A-4(1)	31	10	12.4	56.4	11.1	20.1	97	86	43



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	PL. I.	% BY WEIGHT				% PASSING SIEVES		
							C. SAND	F. SAND	SILT	CLAY	10	40	200
SS- 223	0	124+60	1.11-1.56	A-2-4(0)	19	6	49.9	21.7	16.3	12.0	97	69	30
SS- 224	0	124+60	2.63-3.08	A-4(0)	28	6	0.6	64.8	14.5	20.1	100	100	44
SS- 225	0	124+60	8.71-9.16	A-7-5(18)	53	23	3.8	46.5	21.6	28.1	98	95	75
SS- 229	-1	126+30	1.14-1.59	A-2-4(0)	23	9	56.2	20.3	9.5	14.0	100	62	26
SS- 230	-1	126+30	2.66-3.11	A-6(3)	30	11	2.2	60.2	11.5	26.1	99	97	55
SS- 231	-1	126+30	4.18-4.63	A-6(1)	37	16	0.8	62.8	12.3	24.1	100	99	57
SS- 232	-1	126+30	7.22-7.67	A-2-4(0)	26	NP	0.4	77.5	6.0	16.1	100	100	32
SS- 233	-1	126+30	8.74-9.19	A-4(0)	29	3	2.6	72.6	6.6	18.1	100	98	40