



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-63	CL	25+40	1.36-1.81	A-2-4(0)	28	NP	45.7	29.1	15.2	10.1	96	65	30	-	-
SS-64	CL	25+40	2.88-3.33	A-2-4(0)	33	NP	49.7	29.1	15.2	6.1	96	61	25	-	-

