



SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-95	60 RT	23+20	0.00-0.10	A-7-5(30)	65	33	12.7	10.9	29.9	46.5	100	92	80	-	-
S-96	15 RT	23+00	0.00-0.50	A-7-5(48)	79	40	1.4	3.8	30.1	64.6	100	99	96	-	-
S-97	35 RT	23+00	0.00-0.50	A-7-5(45)	77	37	2.0	3.6	29.7	64.6	100	99	96	-	-

