



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-34	CL	15+74	0.63-1.08	A-4(1)	29	10	33.8	27.8	6.2	32.2	97	78	41	-	-
SS-35	CL	15+74	2.15-2.60	A-4(0)	34	NP	30.4	37.6	13.9	18.1	100	84	41	-	-
SS-36	CL	15+74	6.71-7.26	A-2-4(0)	32	NP	35.8	38.8	13.3	12.1	99	78	33	-	-
SS-45	CL	18+80	0.72-1.17	A-5(1)	42	7	28.6	29.2	10.1	32.2	97	81	46	-	-
SS-46	CL	18+80	2.24-2.69	A-2-4(0)	35	NP	53.1	30.4	4.4	12.1	86	55	18	-	-
SS-47	CL	18+80	3.76-4.21	A-4(0)	36	NP	34.0	35.8	12.1	18.1	100	79	37	-	-
SS-48	CL	18+80	5.28-5.73	A-2-4(0)	35	NP	35.8	41.4	8.7	14.1	100	81	29	-	-
S-49	CL	18+20	0.00-1.20	A-7-6(9)	47	24	26.8	23.3	5.6	44.3	98	84	52	-	-
S-500	5 RT	14+60	0.15-0.45	A-4(0)	33	6	32.8	28.2	18.7	20.3	95	76	41	-	-
S-501	5 RT	14+60	0.50-0.75	A-7-6(6)	44	19	31.0	23.1	17.5	28.4	94	76	48	-	-
S-504	5 RT	14+60	2.55-2.75	A-4(0)	25	8	35.1	29.4	13.3	22.3	97	78	39	-	-
S-505	5 RT	14+60	3.21-3.40	A-2-4(0)	19	NP	51.7	30.4	7.8	10.1	97	69	21	-	-