



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-276	CL	31+40	0.15-0.60	A-7-5(35)	78	44	17.1	10.5	10.1	62.4	100	88	74	-	-
SS-277	CL	31+40	1.07-1.52	A-7-5(4)	43	12	33.4	21.7	20.7	24.1	100	77	49	-	-
SS-278	CL	31+40	2.59-3.04	A-5(0)	43	8	37.8	29.2	18.9	14.1	96	70	36	-	-
SS-279	CL	31+40	4.11-4.56	A-2-4(0)	33	NP	49.9	23.3	14.7	12.1	97	60	30	-	-
SS-280	CL	31+40	5.63-6.08	A-2-4(0)	39	NP	47.3	23.3	17.3	12.1	98	62	33	-	-
S-282	CL	30+80	0.15-1.50	A-7-5(15)	56	23	22.7	14.3	12.7	50.3	100	85	65	-	-
S-283	CL	30+80	2.50-3.50	A-7-6(5)	41	13	29.4	19.9	20.5	30.2	99	79	54	-	-
S-284	CL	30+20	0.50-1.97	A-7-6(8)	45	21	31.2	20.1	14.5	34.2	100	79	52	-	-
S-285	CL	30+20	2.00-3.49	A-7-6(5)	46	21	39.4	20.1	14.3	26.2	100	74	44	-	-
S-286	CL	30+20	4.05-7.00	A-2-4(0)	23	NP	51.3	19.1	15.5	14.1	96	58	31	-	-
SS-287	CL	29+50	0.00-0.45	A-2-4(0)	16	NP	47.7	30.8	11.5	10.1	100	71	26	-	-
SS-288	CL	29+50	1.05-1.50	A-6(5)	37	20	35.6	21.7	14.5	28.2	98	74	45	-	-
SS-289	CL	29+50	2.57-3.02	A-2-4(0)	32	NP	45.9	33.6	14.5	6.0	97	68	26	-	-
S-290	CL	28+80	0.20-2.90	A-7-5(33)	80	40	16.7	12.3	16.7	54.3	100	88	74	-	-
S-291	CL	28+80	3.00-3.94	A-7-5(6)	47	13	29.0	19.9	22.9	28.2	100	80	55	-	-
SS-292	CL	28+10	0.15-0.45	A-2-4(0)	18	NP	46.9	34.6	10.5	8.0	100	68	23	-	-
SS-293	CL	28+10	1.01-1.46	A-2-4(0)	16	NP	45.9	26.4	13.7	14.1	96	66	31	-	-
S-298	CL	26+20	1.00-1.50	A-2-4(0)	20	NP	51.3	24.6	11.9	12.1	98	61	28	-	-
S-299	CL	25+60	0.50-1.00	A-7-5(19)	61	30	22.4	17.0	18.2	42.4	98	84	64	-	-
S-300	CL	25+60	5.00-5.47	A-6(4)	40	13	34.7	20.6	18.4	26.3	93	70	48	-	-
SS-301	CL	25+00	1.12-1.57	A-7-6(9)	55	29	36.8	20.2	12.7	30.3	100	73	46	-	-
SS-302	CL	25+00	2.64-3.09	A-2-4(0)	27	NP	42.2	30.3	15.4	12.1	97	69	33	-	-