



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS- 13	CL	17+20	0.61- 1.06	A- 7- 5(18)	59	27	18.0	18.0	11.6	52.5	100	90	67	-	-
SS- 14	CL	17+20	2.13- 2.58	A- 2- 4(0)	37	NP	38.5	32.7	20.7	8.1	100	76	35	-	-
SS- 15	CL	17+20	6.69- 7.05	A- 2- 4(0)	38	10	42.8	29.3	15.8	12.1	100	70	34	-	-
SS- 16	CL	17+20	9.73- 10.18	A- 2- 4(0)	37	NP	45.2	32.3	10.4	12.1	96	65	27	-	-
S- 17	2.5 LT	17+80	5.54- 7.00	A- 4(1)	39	5	32.5	24.6	18.7	24.2	97	74	46	-	-

10/25/08