



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S- 257	CL	12+20	0. 10- 0. 98	A- 7- 5(28)	67	37	18. 7	11. 5	13. 5	56. 3	100	89	72	-	-
S- 258	CL	12+20	2. 00- 2. 50	A- 4(3)	38	9	30. 6	22. 3	20. 9	26. 2	100	81	50	-	-
SS- 259	CL	11+60	0. 15- 0. 30	A- 2- 4(0)	15	NP	43. 9	33. 0	9. 1	14. 1	98	76	27	-	-
SS- 260	CL	11+60	0. 30- 0. 60	A- 6(6)	39	20	31. 0	21. 9	8. 9	38. 2	100	84	50	-	-
SS- 261	CL	11+60	1. 02- 1. 47	A- 7- 6(6)	43	16	30. 6	21. 5	19. 7	28. 2	100	80	52	-	-
SS- 262	CL	11+60	2. 54- 2. 99	A- 4(0)	32	NP	37. 0	29. 4	21. 5	12. 1	100	78	41	-	-

10/26/08

USE NAME
