



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-257	CL	12+20	0.10-0.98	A-7-5(28)	67	37	18.7	11.5	13.5	56.3	100	89	72	-	-
S-258	CL	12+20	2.00-2.50	A-4(3)	38	9	30.6	22.3	20.9	26.2	100	81	50	-	-
SS-259	CL	11+60	0.15-0.30	A-2-4(0)	15	NP	43.9	33.0	9.1	14.1	98	76	27	-	-
SS-260	CL	11+60	0.30-0.60	A-6(6)	39	20	31.0	21.9	8.9	38.2	100	84	50	-	-
SS-261	CL	11+60	1.02-1.47	A-7-6(6)	43	16	30.6	21.5	19.7	28.2	100	80	52	-	-
SS-262	CL	11+60	2.54-2.99	A-4(0)	32	NP	37.0	29.4	21.5	12.1	100	78	41	-	-
SS-263	CL	11+00	0.00-0.45	A-2-4(0)	15	NP	42.5	32.8	10.7	14.1	98	74	29	-	-
SS-264	CL	11+00	1.06-1.51	A-7-5(8)	52	20	31.2	17.9	20.7	30.2	94	74	51	-	-
SS-265	CL	11+00	2.58-3.03	A-5(0)	46	7	40.4	22.1	21.3	16.1	90	62	38	-	-
S-266	CL	10+40	0.90-1.30	A-7-5(12)	53	16	17.7	20.1	21.9	40.2	100	91	67	-	-
S-296	CL	10+40	3.10-3.93	A-7-5(5)	42	11	24.5	25.6	21.7	28.2	100	87	55	-	-