



SOIL TEST RESULTS

| SAMPLE NO. | OFFSET | STATION | DEPTH INTERVAL | AASHTO CLASS. | LL | P.I. | % BY WEIGHT | | | | % PASSING (SIEVES) | | | % MOISTURE | % ORGANIC |
|------------|--------|---------|----------------|---------------|----|------|-------------|---------|------|------|--------------------|-----|-----|------------|-----------|
| | | | | | | | C. SAND | F. SAND | SILT | CLAY | 10 | 40 | 200 | | |
| S-42 | CL | 10+80 | 2.00-3.50 | A-7-6(3) | 42 | 15 | 31.6 | 23.5 | 10.7 | 34.2 | 88 | 69 | 43 | - | - |
| S-43 | CL | 12+80 | 1.00-1.80 | A-7-6(23) | 65 | 36 | 18.1 | 16.1 | 1.4 | 64.4 | 96 | 85 | 65 | - | - |
| S-44 | CL | 12+80 | 2.00-3.00 | A-7-6(7) | 44 | 17 | 26.0 | 20.7 | 13.1 | 40.2 | 94 | 77 | 54 | - | - |
| S-50 | CL | 13+40 | 0.00-1.00 | A-7-5(35) | 65 | 33 | 2.8 | 15.1 | 49.9 | 32.2 | 100 | 100 | 89 | - | - |