



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-120	CL	19+00	0.79-1.24	A-2-4(0)	28	8	36.4	32.3	7.1	24.2	98	80	35	-	-
SS-121	CL	19+00	2.31-2.76	A-4(1)	40	6	28.5	32.9	16.4	22.2	100	85	45	-	-
SS-122	CL	19+00	3.84-4.29	A-6(1)	40	11	32.7	31.7	19.4	16.2	100	83	41	-	-
SS-123	CL	19+00	5.36-5.81	A-4(0)	39	7	35.4	30.7	17.8	16.2	100	81	39	-	-
SS-124	CL	19+00	6.89-7.34	A-4(0)	38	6	39.0	30.9	16.0	14.1	100	79	37	-	-
SS-161	CL	17+80	0.80-1.25	A-2-6(0)	29	12	43.8	22.4	11.7	22.2	96	67	35	-	-
SS-162	CL	17+80	2.32-2.77	A-6(1)	39	12	40.7	22.4	12.7	24.2	96	65	40	-	-
SS-163	CL	17+80	3.85-4.30	A-2-4(0)	37	7	48.4	29.4	10.1	12.1	95	61	26	-	-
SS-383	6.6 RT	11+34	1.12-1.57	A-7-6(15)	55	28	20.8	25.5	21.4	32.3	100	90	59	-	-
SS-384	6.6 RT	11+34	2.64-3.09	A-4(0)	33	NP	34.3	32.9	26.7	6.1	100	80	39	31.5	-
SS-385	3.6 RT	10+14	1.27-1.72	A-5(5)	52	10	24.0	30.7	25.1	20.2	100	85	53	-	-
SS-386	3.6 RT	10+14	2.79-3.24	A-7-5(4)	49	13	25.5	38.0	8.3	28.3	100	85	47	-	-
SS-485	CL	12+60	1.45-1.90	A-2-6(1)	35	16	48.6	21.3	16.1	14.1	86	55	28	-	-
SS-486	CL	12+60	2.97-3.42	A-2-6(0)	38	12	47.8	24.9	17.1	10.1	95	61	29	-	-
S-487	CL	13+20	0.15-0.79	A-6(3)	26	12	28.0	27.4	20.4	24.3	99	84	49	-	-
S-488	CL	13+20	1.00-2.00	A-7-6(17)	56	32	20.3	23.7	19.6	36.5	99	89	60	-	-
S-489	CL	13+20	3.00-3.50	A-6(4)	38	14	29.0	26.5	18.1	26.3	100	86	50	-	-
SS-490	CL	14+40	0.15-0.60	A-7-6(13)	50	24	20.7	20.3	16.5	42.6	99	87	61	-	-
SS-491	CL	14+40	4.11-4.56	A-7-5(8)	57	21	29.0	27.2	25.6	18.2	97	79	49	-	-