## **SEEDING AND MULCHING:**

(11-21-06

# (West) S-2

The kinds of seed and fertilizer, and the rates of application of seed, fertilizer, and limestone, shall be as stated below. During periods of overlapping dates, the kind of seed to be used shall be determined. All rates are in pounds per acre.

### Shoulder and Median Areas

August 1 - June 1		May 1 - September 1	
20#	Kentucky Bluegrass	20#	Kentucky Bluegrass
75#	Hard Fescue	75#	Hard Fescue
25#	Rye Grain	10#	German or Browntop Millet
500#	Fertilizer	500#	Fertilizer
4000#	Limestone	4000#	Limestone

Areas Beyond the Mowing Pattern, Waste and Borrow Areas:

August 1 - June 1		May 1 - September 1	
100#	Tall Fescue	100#	Tall Fescue
15#	Kentucky Bluegrass	15#	Kentucky Bluegrass
30#	Hard Fescue	30#	Hard Fescue
25#	Rye Grain	10#	German or Browntop Millet
500#	Fertilizer	500#	Fertilizer
4000#	Limestone	4000#	Limestone

# Approved Tall Fescue Cultivars

Adventure	Chieftain	Jaguar	Rebel Jr
Adventure II	Coronado	Jaguar III	Renegade
Amigo	Crossfire II	Kentucky 31	Safari
Anthem	Debutante	Kitty Hawk	Shenandoah
Apache	Duster	Monarch	Tempo
Apache II	Falcon	Montauk	Titan
Arid	Falcon II	Mustang	Tomahawk
Austin	Finelawn	Olympic	Trailblazer
Bonanza	Finelawn I	Pacer	Tribute
Bonanza II	Finelawn Petite	Phoenix	Vegas
Brookstone	Genesis	Pixie	Wolfpack
Bulldog 51	Grande	Pyramid	Wrangler
Chapel Hill	Guardian	Rebel	_
Chesapeake	Houndog	Rebel II	

## Approved Kentucky Bluegrass Cultivars:

Adelphi Columbia Merit Sydsport
Baron Fylking Plush Touchdown
Bristol Glade Ram I Vantage
Challenger Kenblue Rugby

## Approved Hard Fescue Cultivars:

Aurora Nordic Spartan Warwick
Bardur Reliant Valda
Crystal Scaldis Waldina

On cut and fill slopes 2:1 or steeper add 20#Sericea Lespedeza January 1 - December 31.

Fertilizer shall be 10-20-20 analysis. Upon written approval of the Engineer, a different analysis of fertilizer may be used provided the 1-2-2 ratio is maintained and the rate of application adjusted to provide the same amount of plant food as a 10-20-20 analysis.

#### Permanent Soil Reinforcement Mat:

#### General:

This work shall consist of furnishing and placing "Permanent Soil Reinforcement Mat", of the type specified, over previously prepared areas as directed by the Engineer.

### Materials:

The product shall be permanent erosion control reinforcement mat and shall be constructed of 100% coconut fiber stitch bonded between a heavy duty UV stabilized cuspated (crimped) netting overlaid with a heavy duty UV stabilized top net. The three nettings shall be stitched together on 1.5 inch (38 mm) centers UV stabilized polyester thread to form a permanent three dimensional structure. The mat shall have the following physical properties:

Property	Test Method	Value	Unit	
Ground Cover	Image Analysis	93	%	
Thickness	<b>ASTM D1777</b>	0.63 (16)	in (mm)	
Mass Per Unit Area	<b>ASTM D3776</b>	0.92 (0.50)	lb/sy (kg/m2)	
Tensile Strength	<b>ASTM D5035</b>	480 (714.2)	lb/ft (kg/m)	
Elongation	<b>ASTM D5035</b>	49	%	
Tensile Strength	<b>ASTM D5035</b>	960 (1428.5)	lb/ft (kg/m)	
Elongation	<b>ASTM D5035</b>	31	%	
Tensile Strength	<b>ASTM D1682</b>	177 (80.3)	lbs (kg)	
Elongation	<b>ASTM D1682</b>	22	%	
Resiliency	<b>ASTM D1777</b>	>80	%	
UV Stability *	<b>ASTM D4355</b>	151 (68.5)	lbs (kg)	
Color(Permanent Net)		UV Black	. 0,	
Porosity (Permanent Net)	Calculated	>95	%	
Minimum Filament	Measured	0.03 (0.8)	in (mm)	
Diameter (permanent net)				
Elongation Tensile Strength Elongation Resiliency UV Stability * Color(Permanent Net) Porosity (Permanent Net) Minimum Filament	ASTM D5035 ASTM D1682 ASTM D1777 ASTM D4355 Calculated Measured	31 177 (80.3) 22 >80 151 (68.5) UV Black >95	% lbs (kg) % lbs (kg) %	

<sup>\*</sup>ASTM D1682 Tensile Strength and % strength retention of material after 1000 hours of exposure in a Xenon-arc weatherometer.

A certification (Type 1, 2, or 3) from the manufacturer showing:

- 1) the chemical and physical properties of the mat used, and
- 2) conformance of the mat with this specification will be required.

Matting shall be installed according to section 1631-3 of the Standard Specifications.

### Soil Preparation:

All areas to be protected with the mat shall be brought to final grade and seeded in accordance with Section 1660. The surface of the soil shall be smooth, firm, stable and free of rocks, clods, roots or other obstructions which would prevent the mat from lying in direct contact with the soil surface. Areas where the mat is to be placed will not need to be mulched.

#### Measurement:

The quantity of "Permanent Soil Reinforcement Mat" to be paid for shall be the actual number of square yards (square meters), surface measure, completed, and accepted. Overlaps will not be included in the measurement, and will be considered as incidental to the work.

### Basis of Payment:

This work will be paid for at the contract unit price per square yard (square meter) for "Permanent Soil Reinforcement Mat" of the type specified, complete in place and accepted. Such payment shall be full compensation for furnishing and installing the mat in accordance with this specification, and for all required maintenance.

Payment will be made under: