



PROJECT SPECIAL PROVISIONS
Utility Construction

Revise the 2012 *Standard Specifications* as follows:

Utility Owner's Contact Information:

Page 15-1, Subarticle 1500-2 Cooperation with the Utility Owner, paragraph 2, add the following sentences:

There are multiple water and sewer lines on this project that belong to City of Lumberton. The contact person is Rob Armstrong and he can be reached by phone at 910-671-3851.

Water Line Testing and Sterilization:

Page 15-6, 1510-3(B) Subarticle Construction Methods, after line 21, replace the allowable leakage formula with the following:

$$W=LD(\sqrt{P})\div 148,000$$

Page 15-6, 1510-3(B) Subarticle Construction Methods, line 32, delete "concurrently or".

The Contractor shall provide access for the owner's representatives to all phases of construction and keep all valves and meters accessible during construction. A preconstruction meeting shall be held with City of Lumberton, the Utility Contractor and D.O.T prior to any work beginning. The Contractor shall notify the owner two weeks before commencement of any work and three weeks before service interruption.

PROJECT: I-4413
COUNTY: Robeson

PROJECT SPECIAL PROVISIONS

Utility

UTILITY CONFLICTS:

General:

The following utility companies have facilities that will be in conflict with the construction of this project:

- A. AT&T (Telephone)
- B. Time Warner Cable (Cable TV)
- C. City of Lumberton (Power)
- D. Piedmont Natural Gas Company (Gas)
- E. Lumbee River EMC (Power)

The conflicting facilities of these concerns will be adjusted prior to the date of availability, unless otherwise noted and are therefore listed in these special provisions for the benefit of the Contractor. All utility work listed herein will be done by the utility owners. All utilities are shown on the plans from the best available information.

The Contractor's attention is directed to Article 105.8 of the Standard Specifications.

Utilities Requiring Adjustment:

A. AT&T

1. See Utility Conflict Plans by others. The contact person is Mr. Shannon Coston at 910-341-1623.

The proposed telephone line will be adjusted during the installation of the water line shown on profile 3 - (see sheet UC 8). The telephone company prefers to maintain minimum depth through this area only adjusting the telephone line at the proposed water line. AT&T will need two weeks notice and two days to complete the work.

The proposed telephone line crossing the water line shown on profile 1 - (sheet UC-6) shall be installed a minimum of 3' below the proposed water line.

B. Time Warner Cable

1. See Utility Conflict Plans by others. The contact person is Mr. John McMillon at 910-401-5037 (W) or 910-671-3865 (C).

C. City of Lumberton (Power)

1. See Utility Conflict Plans by others. The contact person is Mr. Greg Prevatte at 910-671-3865.

D. Piedmont Natural Gas Company

1. See Utility Conflict Plans by others. The contact person is Mr. Ronnie Love at 910-309-7011.

The proposed gas line crossing the water line shown on profile 1 – (sheet UC-6) shall be installed a minimum of 3' below the proposed water line.

E. Lumbee River EMC

1. See Utility Conflict Plans by others. The contact person is Mr. Bernard Jones at 910-843-4131.