



NOTES:

1. DETAIL SHOWN IS FOR SITUATION WHERE ELECTRICAL SERVICE CONDUCTORS RESIDE IN AN EXCLUSIVE CONDUIT. IF CONDUCTORS ARE FOUND TO SHARE CONDUIT WITH OTHER CABLES/WIRES OR IF EXISTING CONDUIT IS LARGER THAN 1", USE 3/4" LFNC INSTEAD OF 1.25" LFNC AND INSERT 3/4" LFNC A MINIMUM OF 12" INTO EXISTING CONDUIT.

TYPE 4

	High Point Signal System Integrated Base Adapter Detail		
	Division 7 Guilford County High Point	PLAN DATE: June 2015 REVIEWED BY: HA Badgett	
750 Greenfield Parkway, Garner, NC 27529	PREPARED BY: BJ Slocum	REVIEWED BY: SG Haynie	SEAL 6/5/2015 DATE
SCALE: NTS	REVISIONS	INIT. DATE	CADD Filename: ITS-5.11.dgn

04-JUN-2015 16:49
 T:\Product\ITSS\ITS-5.11.dgn
 S:\COC3653 AT_LUS291201